

1. Design guidelines.


AS/NZS 5000.1	Electric cables-Polymeric insulated Part 1: For working voltages up to and including 0.6/1kV(1.2)kV
AS/NZS 1125	Conductors in insulated electric cables and flexible cords
AS/NZS 3808	Insulating and sheathing materials for electric cables

2. Application.

Normal use operating temperature	90°C
Max. conductor temperature during short circuit(5s)	250°C
Lowest recommended temperature during installation	0°C

3. Construction.

HCA - 95mm² x 1 core Cu/XLPE/PVC(Black) 1kV - HCA-QMR95x1CuXP-1



1	Conductor	Class 2, plain annealed circular compacted Copper conductor
2	Insulation	X-90
3	Over sheath	5V-90 Black

4. Core identification and mark as listed below, or as purchase order.

Identification of core: Natural
Marking on cable: by printing in one line on the surface of outer sheath
HENG TONG CABLE AUSTRALIA "YEAR" ELECTRIC CABLE 0.6/1kV HPC-S 95mm ² 1 core Cu XLPE PVC SDI XXXXm



**TECHNICAL DATA SHEET
HENGTONG CABLE AUSTRALIA**

Doc No.:
GD/TC/4120001-2020

Rev: 2

0.6/1kV QMR

Date: 4/25/2023

Page: 2 of 2

5. Construction parameters.

Description	Unit	Values
Conductor		
Material	-	Copper
Nominal cross-sectional area	mm ²	95
Conductor shape	/	Circular Compacted
Approx. diameter of active conductor	mm	11.5
Insulation		
Material	-	X-90
Nominal thickness/Min. thickness at any point	mm	1.1/0.89
Approx. diameter over insulation	mm	13.9
Oversheath		
Material	-	5V-90
Nominal thickness/Min. thickness at any point	mm	1.5/1.18
Approx. diameter of oversheath	mm	16.9
Max. diameter of cable	mm	18.9
Approx. mass of cable	kg/km	977
Electrical data		
Max. D.C. resistance of conductor at 20°C	Ω/km	0.193
Max. A.C. resistance of conductor at 90°C	Ω/km	0.2471
Fault current carrying capacity of conductor	kA/1sec	13.59
Mechanical data		
Maximum pulling tension of conductor	kN	6.46
Min. bending radius during installation	mm	340
Min. bending radius after installed	mm	230