

TECHNICAL DATA SHEET HENGTONG CABLE AUSTRALIA

6.35/11(12) kV PWC

Doc No.: GD/TC/4120001-2020 Rev: 1 Date: 5/18/2023 Page: 1of 3

1. Design guidelines.


AS/NZS 1429.1	Electric cables-Polymeric insulated Part 1: For working voltages 1.9/3.3(3.6) kV up to and including 19/33(36) kV
AS/NZS 1125	Conductors in insulated electric cables and flexible cords
AS/NZS 3808	Insulating and sheathing materials for electric cables

2. Application.

Normal use operating temperature	90°C
Max. conductor temperature during short circuit(5s)	250°C
Lowest recommended temperature during installation	0°C

3. Construction.

HCA - 240mm² x 1 core AI(WBY)/TR-XLPE/WBT/CWS(13.1kA)/WBT/PVC/NY/HDPE(Graphite) - HCA286021PWC



1	Conductor	Class 2, circular compacted Aluminium conductor (non-conductive water-blocking yarn) A Semi-conductive tape shall be applied over the conductor	
2	Conductor screen	Semi-conductive compound	
3	Insulation	TR-XLPE	
4	Insulation screen	Semi-conductive compound	
5	Bedding tape	Semi-conductive water-blocking tape	
6	Metallic screen	Plain annealed copper wire screen	
7	Binder tape	Water-blocking tape	
8	Inner sheath	5V-90 Orange	
9	Insect protection	Nylon 12 / Blue	
10	Outer sheath	HDPE Black (with Graphite on the outer surface)	

4. Core identification and mark as listed below, or as purchase order.

Identification of core: Natural		
Marking on cable: by printing in two diametrically opposed lines on the surface of outer sheath		
HENGTONG CABLE AUSTRALIA "YEAR" ELECTRIC CABLE 6.35/11kV		
240mm² 1 core Al(WBY) TR-XLPE WBT CWS(13.1kA) WBT PVC NY HDPE(Graphite) XXXXm		



TECHNICAL DATA SHEET HENGTONG CABLE AUSTRALIA

6.35/11(12) kV PWC

Doc No.: GD/TC/4120001-2020 Rev: 1 Date: 5/18/2023

Page: 2of 3

5. Construction parameters.

Description	Unit	Values
Active Conductor		
Material	-	Aluminium
Nominal cross-sectional area	mm²	240
Conductor shape	1	Circular Compacted
Approx. diameter of active conductor	mm	18.4
Conductor screen		
Min. thickness at any point	mm	0.3
Approx. diameter of conductor screen	mm	20.4
Active Insulation		
Material	-	TR-XLPE
Nominal thickness/Min. thickness at any point	mm	3.4/2.96
Approx. diameter over insulation	mm	27.2
Insulation screen		
Туре	-	Hand-strippable
Min. thickness at any point	mm	0.6
Approx. diameter of insulation screen	mm	28.7
Metallic screen		
No.& Diameter of copper wires per phase	No./mm	50/1.53
Approx. diameter of metallic screen	mm	32.6
Inner sheath		
Material	-	5V-90
Nominal thickness/Min. thickness at any point	mm	1.0/0.60
Approx. diameter of inner sheath	mm	37.1
Insect protection		
Material	-	Nylon 12
Min. thickness at any point	mm	0.5
Approx. diameter over Insect protection	mm	38.7
Outer sheath		
Material	-	HDPE
Nominal thickness/Min. thickness at any point	mm	2.0/1.40
Approx. diameter of outer sheath	mm	42.9
Max. diameter of cable	mm	45.1
Approx. mass of cable	kg/km	2,620
Electrical data		
Max. D.C. resistance of active conductor at 20℃	Ω/km	0.125
Max. A.C. resistance of conductor at 90 ℃	Ω/km	0.161
Fault current carrying capacity of conductor	kA/1sec	22.7
Fault current carrying of screen	kA/1sec	13.1



TECHNICAL DATA SHEET HENGTONG CABLE AUSTRALIA

Doc No.: GD/TC/41

GD/TC/4120001-2020

Rev: 1

Date: 5/18/2023

Page: 3of 3

6.35/11(12) kV PWC

· ·		
Description	Unit	Values
Mechanical data		
Maximum pulling tension of conductor	kN	9.4
Min. bending radius during installation	mm	1160
Min. bending radius after installed	mm	770