

TECHNICAL DATA SHEET HENGTONG CABLE AUSTRALIA

Doc No.: 6612001CXCPNP-13.5 Rev: 0

38/66(72.5) kV PWC

Date: 6th January 2022

Page: 1of 2

1. Design guidelines.


AS/NZS 1429.2	Electric cables—Polymeric insulated	
A3/INZ3 1429.2	Part 2: For working voltages above 19/33 (36) kV up to and including 87/150(170) kV	
AS/NZS 1125	Conductors in insulated electric cables and flexible cords	
AS/NZS 3808	Insulating and sheathing materials for electric cables	

2. Application.

Normal use operating temperature	90°C
Max. conductor temperature during short circuit(5s)	250°C
Lowest recommended temperature during installation	0°C

3. Construction.

HCA - 1200mm² x 1 core Cu(M)(WBY)/XLPE/CAS(13.5kA)/MDPE/NY/HDPE(Graphite) - HCA503103PWC



1	Conductor	Class 2, circular Milliken Copper conductor(non-conductive water-blocking yarn)		
I	Conductor	A Semi-conductive tape shall be applied over the conductor		
2	Conductor screen Semi-conductive tape and compound			
3	Insulation XLPE			
4	Insulation screen	Semi-conductive compound		
5	Water blocking Semi-conductive water-blocking tape			
6	Metallic sheath Corrugated Aluminum sheath			
7	Inner sheath MDPE/Orange			
8	Anti-termite sheath	ti-termite sheath Nylon (PA12)/Blue		
9	Outer sheath	HDPE/Black with 2% carbon black		
10	Outer conductive layer	Graphite coating		

4. Cable mark as listed below, or as purchase order.

Marking on cable: by printing in two approximately diametrically opposed lines on the surface of outer sheath HENGTONG CABLE AUSTRALIA "YEAR" ELECTRIC CABLE 38/66kV 1200mm² 1 core Cu(M)(WBY) XLPE CAS(13.5kA) MDPE NY HDPE(Graphite) XXXXm



TECHNICAL DATA SHEET HENGTONG CABLE AUSTRALIA

Doc No.: 6612001CXCPNP-13.5 Rev: 0

38/66(72.5) kV PWC

Date: 6th January 2022 Page: 2of 2

5. Construction parameters.

Description	Unit	Values
Conductor		
Cross sectional area	mm ²	1200
Shaped	/	Circular
Number of wires	No.	≥53
Approx. diameter of conductor	mm	41.4
Conductor screen		
Min. thickness at any point	mm	1.8
Approx. diameter over conductor screen	mm	45.8
Insulation		
Nominal thickness/Min. thickness at any point	mm	10.0/8.9
Approx. diameter over insulation	mm	65.8
Insulation screen		
Туре		Fully bonded
Min. thickness at any point	mm	1.0
Approx. diameter over insulation screen	mm	67.8
Metallic sheath		
Nominal thickness/Min. thickness at any point	mm	2.3/1.9
Approx. diameter over corrugated aluminum sheath	mm	85.3
Inner sheath (MDPE)		
Nominal thickness/Min. thickness at any point	mm	4.0/3.3
Approx. diameter over MDPE sheath	mm	93.3
Anti-termite sheath (PA12)		
Nominal thickness/Min. thickness at any point	mm	1.3/0.8
Approx. diameter over nylon sheath	mm	95.9
Outer sheath (HDPE w/ graphite)		
Nominal thickness/Min. thickness at any point	mm	3.0/2.2
Approx. diameter over HDPE sheath	mm	101.9
Max. diameter of cable	mm	106.9
Min. bending radius during installation	mm	2877
Min. bending radius after installed	mm	1918
Max. D.C. resistance of conductor at 20°C	Ω/km	0.0151
Max. A.C. resistance of conductor at 90°C	Ω/km	0.0218
Fault current carrying capacity of conductor for 1 second	kA	171.7
Fault current carrying capacity of metallic screen for 1 second	kA	13.5
Maximum pulling tension of conductor	kN	84.0
Cable weight	kg/m	17.5