


1. Design guidelines.

AS/NZS 4026	Electric cables-For underground residential distribution systems
AS/NZS 5000.1	Electric cables-Polymeric insulated Part 1: For working voltages up to and including 0.6/1kV (1.2) kV
AS/NZS 1125	Conductors in insulated electric cables and flexible cords
AS/NZS 3808	Insulating and sheathing materials for electric cables

2. Application.

Normal use operating temperature	90°C
Max. conductor temperature during short circuit(5s)	250°C
Lowest recommended temperature during installation	0°C

3. Construction.
HCA - 16mm² x 4 core Cu XLPE PVC(Black) 1kV - HCA20365EQL


1	Conductor	Class 2, plain annealed circular compacted Copper conductor
2	Insulation	X-90
3	Over sheath	5V-90 Black

4. Core identification and mark as listed below, or as purchase order.

Identification of core: Black, Red, White, Blue
Marking on cable: by printing in one line on the surface of outer sheath
HENGTONG CABLE AUSTRALIA "YEAR" ELECTRIC CABLE ENERGEX 406 0.6/1kV 16mm ² x 4 Core Cu XLPE PVC XXXXm



**TECHNICAL DATA SHEET
HENGTONG CABLE AUSTRALIA**

Doc No.:
GD/TC/4120001-2021

Rev: 0

0.6/1kV EQL

Date: 4/25/2023

Page: 2 of 2

5. Construction parameters.

Description	Unit	Values
Active Conductor		
Material	-	Copper
Nominal cross-sectional area	mm ²	16
Conductor shape	/	Circular Compacted
Approx. diameter of active conductor	mm	4.8
Active Insulation		
Material	-	X-90
Nominal thickness/Min. thickness at any point	mm	1.5/1.25
Approx. diameter over insulation	mm	8.0
Laying up of cores		
Direction of lay		Right
Diameter of laid up core	mm	19.8
Oversheath		
Material	-	5V-90
Nominal thickness/Min. thickness at any point	mm	1.8/1.00
Approx. diameter of oversheath	mm	23.4
Max. diameter of cable	mm	25.4
Approx. mass of cable	kg/km	877
Electrical data		
Max. D.C. resistance of active conductor at 20°C	Ω/km	1.15
Max. A.C. resistance of conductor at 90°C	Ω/km	1.47
Fault current carrying capacity of conductor	kA/1sec	2.29
Mechanical data		
Maximum pulling tension of conductor	kN	4.35
Min. bending radius during installation	mm	150
Min. bending radius after installed	mm	100