

## TECHNICAL DATA SHEET HENGTONG CABLE AUSTRALIA

### 38/66(72.5) kV PWC

Doc No.: 666301CXCPNP-13.5

Rev: 0

Date: 6th January 2022

Page: 1of 2

#### 1. Design guidelines.


AS/NZS 1429.2	Electric cables—Polymeric insulated	
A3/NZ3 1429.2	Part 2: For working voltages above 19/33 (36) kV up to and including 87/150(170) kV	
AS/NZS 1125	Conductors in insulated electric cables and flexible cords	
AS/NZS 3808	Insulating and sheathing materials for electric cables	

#### 2. Application.

Normal use operating temperature	90°C
Max. conductor temperature during short circuit(5s)	250°C
Lowest recommended temperature during installation	0°C

#### 3. Construction.

#### HCA - 630mm² x 1 core Cu(WBY)/XLPE/CAS(13.5kA)/MDPE/NY/HDPE(Graphite) - HCA503101PWC



1	Conductor	Class 2, circular compacted Copper conductor(non-conductive water-blocking		
	Conductor	yarn) A Semi-conductive tape shall be applied over the conductor		
2	Conductor screen	Semi-conductive tape and compound		
3	Insulation	XLPE		
4	Insulation screen	Semi-conductive compound		
5	Water blocking	Semi-conductive water-blocking tape		
6	Metallic sheath	Corrugated Aluminum sheath		
7	Inner sheath	MDPE/Orange		
8	Anti-termite sheath	Nylon (PA12)/Blue		
9	Outer sheath	HDPE/Black with 2% carbon black		
10	Outer conductive layer	Graphite coating		

#### 4. Cable mark as listed below, or as purchase order.

Marking on cable: by printing in two approximately diametrically opposed lines on the surface of outer sheath
HENGTONG CABLE AUSTRALIA "YEAR" ELECTRIC CABLE 38/66kV
630mm² 1 core Cu(WBY) XLPE CAS(13.5kA) MDPE NY/HDPE(Graphite) XXXXm



# TECHNICAL DATA SHEET HENGTONG CABLE AUSTRALIA

### 38/66(72.5) kV PWC

Doc No.: 666301CXCPNP-13.5 Rev: 0

Date: 6th January 2022

Page: 2of 2

#### 5. Construction parameters.

Description	Unit	Values
Conductor		
Cross sectional area		630
Shaped		Circular
Number of wires		≥53
Approx. diameter of conductor		30.2
Conductor screen		
Min. thickness at any point		1.1
Approx. diameter over conductor screen	mm	32.9
Insulation		
Nominal thickness/Min. thickness at any point	mm	11.0/9.8
Approx. diameter over insulation		54.9
Insulation screen		
Туре		Fully bonded
Min. thickness at any point	mm	1.0
Approx. diameter over insulation screen	mm	56.9
Metallic sheath		
Nominal thickness/Min. thickness at any point	mm	2.0/1.6
Approx. diameter over corrugated aluminum sheath	mm	73.3
Inner sheath (MDPE)		
Nominal thickness/Min. thickness at any point	mm	4.0/3.3
Approx. diameter over MDPE sheath	mm	81.3
Anti-termite sheath (PA12)		
Nominal thickness/Min. thickness at any point		1.3/0.8
Approx. diameter over nylon sheath		83.9
Outer sheath (HDPE w/ graphite)		
Nominal thickness/Min. thickness at any point	mm	3.0/2.2
Approx. diameter over HDPE sheath	mm	89.9
Max. diameter of cable		94.9
Min. bending radius during installation		2517
Min. bending radius after installed		1678
Max. D.C. resistance of conductor at 20°C		0.0283
Max. A.C. resistance of conductor at 90°C		0.0385
Fault current carrying capacity of conductor for 1 second		90.1
Fault current carrying capacity of metallic screen for 1 second		13.5
Maximum pulling tension of conductor	kN	44.1
Cable weight		11.2